



NOTES:

1. CONSTRUCT PLENUM TO SUPPORT WEIGHT OF SERVICE TECHNICIAN.
2. SEAL JOINTS WATER TIGHT AT BOTTOM OF WALL SLEEVE AND PLENUM.
3. INSULATE PLENUM AND DUCTS AS SPECIFIED.



PLENUM CONSTRUCTION DETAIL

NOT TO SCALE

23 37 00-2

PLENUM CONSTRUCTION DETAIL

Date: June 22, 2010

Dwg. No.: 23 37 00-2