


**NOTES:**

1. PIPE INSULATION SHALL BE CONTINUOUS THROUGH PENETRATIONS.



# PIPE PENETRATION - INTERIOR WALL

NOT TO SCALE

23 05 17-01

PIPE PENETRATION - INTERIOR WALL

Date: OCTOBER 1, 2017

Dwg. No.: 23 05 17-01