


NOTES:

1. PIPE INSULATION SHALL BE CONTINUOUS THROUGH PENETRATIONS. PROVIDE RIGID THERMAL HANGAR SHIELD INSERT AT MODULAR SLEEVE SEALS.



PIPE PENETRATION - EXTERIOR WALL

NOT TO SCALE

23 05 17-03

PIPE PENETRATION - EXTERIOR WALL

Date: OCTOBER 1, 2017

Dwg. No.: 23 05 17-03