


NOTES:

1. PIPE INSULATION SHALL BE CONTINUOUS THROUGH PENETRATIONS.



PIPE PENETRATION - FLOOR

NOT TO SCALE

23 05 17-04

PIPE PENETRATION - FLOOR

Date: OCTOBER 1, 2017

Dwg. No.: 23 05 17-04