



GLOBAL REFERENCE POINTS:

OUTSIDE AIR REFERENCE DRY BULB TEMPERATURE:

- LOCATE ON THE EXTERIOR NORTH SIDE OF THE BUILDING. LOCATION MUST BE SHADED AWAY FROM ANY HEAT SOURCE. LOCATION TO BE DETERMINED PER MANUFACTURER'S RECOMMENDATIONS AND ARCHITECT/ENGINEER'S APPROVAL. CONTRACTOR SHALL PRIME AND PAINT THE DEVICE ENCLOSURE. COLOR SELECTION BY ARCHITECT/ENGINEER.

OUTSIDE AIR REFERENCE CARBON DIOXIDE:

- LOCATE ON THE EXTERIOR OF THE BUILDING. LOCATION TO BE DETERMINED PER MANUFACTURER'S RECOMMENDATIONS AND ARCHITECT/ENGINEER'S APPROVAL. CONTRACTOR SHALL PRIME AND PAINT THE DEVICE ENCLOSURE. COLOR SELECTION BY ARCHITECT.

OUTSIDE AIR REFERENCE HUMIDITY:

- LOCATE ON THE EXTERIOR OF THE BUILDING. LOCATION TO BE DETERMINED PER MANUFACTURER'S RECOMMENDATIONS AND ARCHITECT/ENGINEER'S APPROVAL. CONTRACTOR SHALL PRIME AND PAINT THE DEVICE ENCLOSURE. COLOR SELECTION BY ARCHITECT.

BUILDING DIFFERENTIAL PRESSURE:

- INPUTS TO THE DIFFERENTIAL PRESSURE SENSOR SHALL BE THE AVERAGE OUTSIDE AIR PRESSURE AND THE AVERAGE INTERIOR AIR PRESSURE. PIPING BY HEATING CONTRACTOR. FINAL LOCATIONS (MINIMUM 4) TO BE DETERMINED PER MANUFACTURER'S RECOMMENDATIONS AND ARCHITECT/ENGINEER'S APPROVAL. CONTRACTOR SHALL PRIME AND PAINT THE DEVICE ENCLOSURES. COLOR SELECTION BY ARCHITECT.



BUILDING PRESSURE SENSOR (S.O.A.P.)

NOT TO SCALE

23 09 05-13

BUILDING PRESSURE SENSOR (STATIC OUTSIDE AIR PROBE)

Date: August 1, 2016

Dwg. No.: 23 09 05-13