



- NOTES:**
- TYPICAL FOR TWO OR MORE COILS.
 - PIPING IS DIAGRAMMATIC IN NATURE.
 - ALL CHECK VALVES SHALL BE INSTALLED WITH FLOW HORIZONTAL OR VERTICALLY UPWARD.
 - VENT AND DRAIN PIPING SHALL BE SAME SIZE AS COIL CONNECTION AND SHALL BE EXTENDED AS REQUIRED FOR ACCESS TO VALVE (TYP.)

PUMPED HEATING COIL DETAIL - MULTIPLE COILS

XX

NOT TO SCALE

23 21 00-02

0	6/24/10	ORIGINAL ISSUE
#	DATE	REVISION DESCRIPTION

PUMPED HEATING COIL DETAIL - MULTIPLE COILS

Date: June 15, 2013

Dwg. No.: 23 21 00-02