



- NOTES:**
- PIPING IS DIAGRAMMATIC IN NATURE.
 - ALL CHECK VALVES SHALL BE INSTALLED WITH FLOW HORIZONTAL OR VERTICALLY UPWARD.
 - VENT AND DRAIN PIPING SHALL BE SAME SIZE AS COIL CONNECTION AND SHALL BE EXTENDED AS REQUIRED FOR ACCESS TO VALVE (TYP.)

PUMPED HEATING COIL DETAIL - SINGLE COIL

XX

NOT TO SCALE

23 21 00-03

#	DATE	REVISION DESCRIPTION
0	6/24/10	ORIGINAL ISSUE

PUMPED HEATING COIL DETAIL - SINGLE COIL

Date: June 15, 2013

Dwg. No.: 23 21 00-03