

EXHIBIT 23 09 23-01A, EXAMPLE BUILDING MAIN NAVIGATION SCREEN

VER - Main - Mozilla Firefox

History Bookmarks Tools Help

illinois.edu https://g3web1.fssc.illinois.edu/ord?station:|slot:;Drivers/NiagaraNetwork/B198\_PPSB/B198\_1\_PPSB/points/Main|view:Main

VER - Main UIUC - VAV

ion (UIUC\_ENS\_SERVER) Config Drivers NiagaraNetwork B198\_PPSB B198\_1\_PPSB Points Main

**ILLINOIS**  
UNIVERSITY OF ILLINOIS AT URBANA-CHAMPAIGN

Physical Plant Services Bldg. 198

87.0 °F Fair  
 OA Humidity 57.0 %RH  
 OA Dew Point 70.0 °F  
 OA Enthalpy 38.2 BTU/lb

Floor Plans Logs

|                                |          |        |
|--------------------------------|----------|--------|
| <a href="#">AHU-12</a>         | Occupied | Normal |
| <a href="#">AHU-14</a>         | Occupied | Normal |
| <a href="#">AHU-15</a>         | Occupied | Normal |
| <a href="#">AHU-16</a>         | Occupied | Normal |
| <a href="#">AHU-17</a>         | Occupied | Normal |
| <a href="#">AHU-18</a>         | Occupied | Normal |
| <a href="#">AHU-19</a>         | Occupied | Normal |
| <a href="#">AHU-20</a>         | Occupied | Normal |
| <a href="#">HX-1</a>           | Enabled  | Normal |
| <a href="#">HX-2</a>           | Enabled  | Normal |
| <a href="#">20 Ton Chiller</a> | Enabled  | Normal |

[VAV Navigation Screen](#)

[Chilled Water Entrance](#)

[Utilities](#)

|                     |                      |
|---------------------|----------------------|
| CHWS Temp: 40.51 °F | Flow: 124.41 gal/min |
| CHWR Temp: 56.54 °F | Tons: 83.3 tR-hr     |