

EXHIBIT 23 09 23-05A, EXAMPLE VAV SUMMARY TABLE

Physical Plant Services Bldg.198
 AHU-20 VAV's
 1st Floor Construction Services

87.0 °F
 Fair

AHU-20 Loc. Room 1800B
 Status: Occupied
 Supply Temp: 56.2 °F
 Supply Static: 1.0 in/wc

	Occ Sensor	Room Temp	Room Setpt	Flow	Aux. Temp
Conf. Room 1830: VAV-1	Occ	70.2 °F	70.8 °F	422.0 cfm	63.9 °F
Rooms 1840-1848: VAV-2	Occ	74.4 °F	67.8 °F	965.0 cfm	56.7 °F
Room 1850: VAV-3	Occ	73.6 °F	71.5 °F	2052.0 cfm	57.2 °F
Room 1849: VAV-4	Occ	74.7 °F	71.0 °F	425.0 cfm	57.3 °F
Receiving Room 1860: VAV-5	Occ	84.9 °F	73.9 °F	516.0 cfm	59.6 °F