



BUSINESS INSTRUCTIONAL FACILITY LOC. 1206  
 FIRST and SECOND FLOOR VAV SUMMARY PAGE  
 SERVED by AHU3

OUTSIDE AIR TEMP 56.3 DEG F  
 OUTSIDE HUMIDITY 75.51 %RH  
 OA DEWPOINT 49.4 DEG F  
 OA ENTHALPY 21.29 BTU/LB



BUSINESS INSTC. FACILITY MAIN PAGE AIR HANDELING UNIT 3 GRAPHICS

ACADEMIC CALENDER MODE



Schedule Value Last 30 days

UIUC.SCHED.VALUE 4

SUPPLY AIR TEMP 60.4 DEG F

SUP STATIC 1.50 IN WC

MODE OCC1

ROOM #	OCC.SNS	RM.TEMP	RM.STPT	FLOW	AUX.TEMP
1035K	ON	73.50 DEG F	72.75 DEG F	60.00 CFM	61.50 DEG F
1035L	ON	71.75 DEG F	72.00 DEG F	88.00 CFM	72.50 DEG F
1035N	ON	68.50 DEG F	70.25 DEG F	76.00 CFM	61.50 DEG F
1035M	ON	73.25 DEG F	73.50 DEG F	48.00 CFM	61.50 DEG F
1035P	ON	72.75 DEG F	73.25 DEG F	92.00 CFM	80.00 DEG F
1035O	ON	71.25 DEG F	71.25 DEG F	120.00 CFM	61.50 DEG F
1035Q	ON	73.00 DEG F	73.00 DEG F	64.00 CFM	68.00 DEG F
1041	ON	75.50 DEG F	75.00 DEG F	320.00 CFM	61.50 DEG F
1044	ON	70.25 DEG F	70.00 DEG F		
2010		75.00 DEG F	75.00 DEG F	386.00 CFM	69.00 DEG F
2013		75.00 DEG F	75.00 DEG F	496.00 CFM	74.50 DEG F
2002A	OFF	73.50 DEG F	75.00 DEG F	48.00 CFM	61.50 DEG F
2008	ON	74.50 DEG F	75.00 DEG F	68.00 CFM	61.50 DEG F
2009	OFF	74.25 DEG F	75.00 DEG F	152.00 CFM	61.00 DEG F
2002B	OFF	75.00 DEG F	75.00 DEG F	104.00 CFM	61.50 DEG F
2006	ON	73.00 DEG F	72.00 DEG F	64.00 CFM	61.00 DEG F
2003	ON	74.50 DEG F	75.00 DEG F	180.00 CFM	
2002B	OFF	72.75 DEG F	72.00 DEG F	80.00 CFM	63.00 DEG F
2015	ON	75.25 DEG F	78.00 DEG F	76.00 CFM	100.50 DEG F
2016	OFF	72.75 DEG F	72.00 DEG F	264.00 CFM	61.00 DEG F
2015C	ON	72.50 DEG F	72.00 DEG F	56.00 CFM	61.00 DEG F
2015B	OFF	77.00 DEG F	76.00 DEG F	0.00 CFM	73.50 DEG F
2015D	ON	74.25 DEG F	75.00 DEG F	48.00 CFM	61.50 DEG F
2015E	ON	73.25 DEG F	75.00 DEG F	204.00 CFM	61.00 DEG F

ROOM #	OCC.SNS	RM.TEMP	RM.STPT	FLOW	AUX.TEMP
2017	OFF	72.25 DEG F	72.00 DEG F	440.00 CFM	68.50 DEG F
2017A	OFF	69.25 DEG F	75.00 DEG F	84.00 CFM	61.50 DEG F
2015F	ON	76.50 DEG F	75.00 DEG F	104.00 CFM	81.00 DEG F
2019A	OFF	71.25 DEG F	72.00 DEG F	0.00 CFM	66.00 DEG F
2019	OFF	75.00 DEG F	75.00 DEG F	0.00 CFM	69.00 DEG F
2019C	ON	72.25 DEG F	72.00 DEG F	48.00 CFM	61.50 DEG F
2019B	OFF	81.00 DEG F	75.00 DEG F	100.00 CFM	61.00 DEG F
2019D	ON	77.00 DEG F	79.25 DEG F	0.00 CFM	93.50 DEG F
2019E	ON	73.25 DEG F	72.00 DEG F	48.00 CFM	61.50 DEG F
2019G	ON	73.00 DEG F	72.00 DEG F	48.00 CFM	61.00 DEG F
2019F	ON	74.00 DEG F	75.00 DEG F	56.00 CFM	61.50 DEG F
2019H	OFF	72.50 DEG F	72.00 DEG F	0.00 CFM	66.00 DEG F
2019J	ON	74.75 DEG F	75.00 DEG F	120.00 CFM	62.50 DEG F
2019K	OFF	76.25 DEG F	77.00 DEG F	48.00 CFM	104.50 DEG F
2019L	OFF	77.50 DEG F	77.00 DEG F	80.00 CFM	61.50 DEG F
2019I	ON	72.50 DEG F	72.00 DEG F	0.00 CFM	78.00 DEG F
2015A	ON	72.75 DEG F	72.00 DEG F	60.00 CFM	60.00 DEG F
2021C	ON	74.75 DEG F	72.00 DEG F	80.00 CFM	61.50 DEG F
2021E	ON	73.75 DEG F	72.00 DEG F	76.00 CFM	62.50 DEG F
2021G	ON	72.50 DEG F	72.00 DEG F	224.00 CFM	61.50 DEG F
2021F	ON	72.50 DEG F	72.00 DEG F	80.00 CFM	61.50 DEG F
2021D	ON	73.25 DEG F	72.00 DEG F	80.00 CFM	62.50 DEG F
2021A	ON	73.50 DEG F	72.00 DEG F	80.00 CFM	62.50 DEG F
2021H	ON	72.75 DEG F	72.00 DEG F	56.00 CFM	64.00 DEG F