

GENERAL POINT NAMING (22 characters maximum)										
example #	AREA NOT USED	constant B	sub bldg. id no leading zeros	system type AHU, HX,	system id no leading zeros	system section	system device	action		
1		B	2	AHU	21	DA	TEMP	SP		
2		B	11	RHW	1	SPPLY	TEMP			
3				AHU	12	CLG	VLV			
4		OMMITTED WHEN NOT USED			AHU	2	PHT	PG		
5				AHU	465	MODE	HTG	SP		
6				AHU	5	SF	S/S			
7				AHU	7	RF	VFD	FLT		
EXAMPLE AND DESCRIPTION										
1	B2_AHU21_DA_TEMP_SP	=		Building 2, Air Handling Unit 21 Discharge Air Temperature Set Point						
2	B11_RHW1_SPPLY_TEMP	=		Building 11, Reheat Water System 1, Supply Temperature						
3	AHU12_CLG_VLV	=		Air Handling Unit 12 Cooling Valve						
4	AHU2_PHT_PG	=		Air Handling Unit 2 Preheat Proportional Gain						
5	AHU465_MODE_HTG_SP	=		Air Handling Unit 465 Mode Heating Set Point						
6	AHU5_SF_S/S	=		Air Handling Unit 5 Supply Fan, Start / Stop						
7	AHU7_RF_VFD_FLT	=		Air Handling Unit 7 Return Fan Variable Frequency Drive, Fault						