

SECTION 07 50 00 - MEMBRANE ROOFING

PART I - GENERAL

1.1 WARRANTY

- A. Provide a 2 year Contractor Installation Warranty.

PART 2 - PRODUCTS

2.1 SYSTEMS

A. Built-up Roofing

1. If a built-up system is chosen, system shall have a minimum of 3 or 4 plies.
2. Coal Tar Pitch: Coal tar is *not* an acceptable roofing product.

B. EPDM

1. Thickness: Minimum thickness is 60 mils.
2. Type of Systems: All roofs shall be fully adhered. Ballasted is not acceptable. Mechanically attached is not acceptable.
3. Field Laps: All field laps are to have 5-inch cover tape installed over them.

PART 3 - EXECUTION

3.1

END OF SECTION 07 50 00

This section of the *U of I Facilities Standards* establishes minimum requirements only.
It should not be used as a complete specification.