

SECTION 09 77 00 - SPECIAL WALL SURFACES

PART I - GENERAL

1.1 RELATED DRAWINGS

- A. *Section 01 78 23 – Operation and Maintenance Data*

1.2 SUBMITTALS

- A. Submittals for all wall surfaces shall be provided to Owner for approval prior to application.
- B. Once submittals have been approved, detailed information on product and application shall be given to the Owner for the purpose of future maintenance.

PART 2 - PRODUCTS

2.1 FINISHES

- A. Due to maintenance considerations, all walls and ceilings shall be smooth plaster or drywall unless a match is being made to existing walls which have a sand finish.
- B. Materials:
 - 1. Textured finishes such as vermiculite, pearlite, polystyrene, and all textured materials either sprayed or applied by hand shall be readily available. Products such as Multispec or Tolaflec are not acceptable.
 - 2. Exterior Insulation: Finish systems are specifically prohibited in all exterior applications. Stucco or direct applied finish systems may be used at exterior ceilings (such as recessed entries) only..

2.2 BLOCK FILLER

- A. Block walls shall be painted with 2 coats of block filler. Concrete walls that have honeycomb, pits or rock pockets shall be rubbed smooth and 1 coat of block filler applied.

PART 3 - EXECUTION

3.1 INSTALLERS

- A. Engage an experienced Contractor who has completed wall surface applications similar in material, design, and extent to that indicated for Project that have resulted in construction with a record of successful in-service performance. Experienced craftsmen shall apply all finishes.

PART 4 - SUBMITTALS

4.1 SCHEDULES

- A. *[Note to AE: Ensure schedules are submitted which will enable the replication or reorder of any manufactured product per Section 01 01 78 23 – Operation and Maintenance Data]*

END OF SECTION 09 77 00

This section of the *U of I Facilities Standards* establishes minimum requirements only.
It should not be used as a complete specification.